



Jim Doyle, Governor  
Mary P. Burke, Secretary

August 19, 2004

NTA, INC.  
DAVID BARTS  
305 N OAKLAND AVE.  
PO BOX 490  
NAPPANEE IN 46550

ROCHESTER HOMES INCORPORATED  
ENGINEERING DEPT  
BRIAN UNGERER  
1345 N LUCAS ST  
PO BOX 587  
ROCHESTER IN 46975

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: ROCHESTER HOMES INCORPORATED  
Product Name: MFG HOME  
Model Number(s): HTS13  
Product File No: 20040444

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 40 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov